

On Site Data Verification Report

Date of Verification: 05-10-2021 Time: 5:15 PM

Site Name: PARALLEL DELHI BRANCH Station Number HRID: 1607

FSL (maximum depth of the canal) 10.66 Max Discharge 5545

Distance between RTDAS and where ADCP is done: 50 ft DOWNSTREAM

Distance between RTDAS and where Manual Gage is available: _____

Note: 1 Cumec = 35.31 Cusec and 1m = 3.28 ft

	ADCP Measurement	Staff Gage Measurement (to be done at RTDAS location, GPS tagged photo mandatory)	Manual Gage Measurement	RTDAS Measurement
Level (ft)	5.2972		4.98	
Discharge (Cusec)	929.42		1200	

We certify that the above measurements are recorded in our presence and that we accept the results and the methodology adopted.

Site responsible JE/SDO Name: <u>Vivek Goyal JE Muzak</u>	Prepared by: <u>RAHUL</u>
Mobile: <u>991999625</u>	<u>05-10-2021</u>
Sign: <u>[Signature]</u>	