

On Site Data Verification Report

Date of Verification: 14-01-2022

Time: 02:30 PM

Site Name BALAK MINOR

Station Number HRID 1532

FSL (maximum depth of the canal) _____

Max Discharge _____

Distance between RTDAS and where ADCP is done : _____

Distance between RTDAS and where Manual Gage is available : _____

Note: 1 Cumec = 35.31 Cusec and 1m = 3.28 ft

	ADCP Measurement	Staff Gage Measurement (to be done at RTDAS location, GPS tagged photo mandatory)	Manual Gage Measurement	RTDAS Measurement
Level (ft)	2.7 FT		2.9 FT	
Discharge (Cusec)	165 Cusec		153 Cusec	

We certify that the above measurements are recorded in our presence and that we accept the results and the methodology adopted.

Site responsible JE/SDO Name: JE Dinesh

Mobile: 9416988947

Sign: Dinesh

Prepared by: RAHUL

Rahul
14-01-2022